



Product Service

CERTIFICATE

No. Z2 104598 0019 Rev. 00

Holder of Certificate: **Mysolar Manufacturing (Shanghai)Co.,Ltd.**
Room 505-A, Fl 5th, No.507, Wuning Rd, Putuo District
200063 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262402601-00

Valid until: 2028-11-09

Date, 2024-01-29

(Zhulin Zhang)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

CERTIFICATE

No. Z2 104598 0019 Rev. 00

Model(s):

Framed 210 N cell modules (STC)
MSxxxN-HJTGB(xxx=640-730 in step of 5)
MSxxxNB-HJTGB(xxx=600-665 in step of 5)
MSxxxNA-HJTGB(xxx=555-605 in step of 5)
MSxxxNF-HJTGB(xxx=545-595 in step of 5)
MSxxxNG-HJTGB(xxx=500-550 in step of 5)
MSxxxNE-HJTGB(xxx=480-535 in step of 5)
MSxxxNH-HJTGB(xxx=450-500 in step of 5)
MSxxxNI-HJTGB(xxx=395-445 in step of 5)
Framed 182 N cell modules (STC)
MSxxxNC-HJTAB(xxx=560-590 in step of 5)
MSxxxN-HJTAB(xxx=520-540 in step of 5)
MSxxxNB-HJTAB(xxx=470-490 in step of 5)
MSxxxNF-HJTAB(xxx=420-445 in step of 5)
Framed 210 M cell modules (STC)
MSxxxM-DHBG(xxx=640-670 in step of 5)
MSxxxM-DHBG(xxx=580-610 in step of 5)
MSxxxM-DHBG(xxx=520-550 in step of 5)
MSxxxM-DHBG(xxx=460-490 in step of 5)
xxx is standing for rated output power at STC

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co.,Ltd No.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, China
Construction:	Framed, double glass with Junction box, cable and connectors.
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016